



# PERFORMANCE BULLETIN

Product     Application     Service     General    news from



January 20, 2000

## 6600/6700 Valves Change to 24 Volt Only

The ordering of 6600 and 6700 valves will be simplified as of February 1, 2000, by reducing valve-operating voltage options from three to one. The 24-volt option will be retained and the 120-volt and 220-volt options will be eliminated. This is due to lack of availability of 120-volt and 220-volt circuit boards from our suppliers.

The following options will be available for these valves:

- 24 volt wires – less cord/transformer (Price Deduct)
- Transformer, US plug 120 volt/24 volt 50/60Hz (Priced the same as our current 120 volt power cord option) (No Adder)
- Transformer, European plug 220 volt/24 volt 50/60Hz (Price Adder)

We will provide replacement parts (120-volt and 220-volt) for valves under warranty. However, it will be necessary to use 24-volt powerheads to replace out of warranty 6600 and 6700 valves.

Enclosed you will also find a copy of the new Service Manual for 6600/6700 control valves. The date of this new revision is 2-12/99.

As always, thank you for using Fleck controls.

Sincerely,  
Pentair Water Treatment, Inc.

Jay Runkle  
Technical Product Support

