



# PERFORMANCE BULLETIN

Product     Application     Service     General    news from



April 12, 2001

## Brass Spacers on 2850 and 9500 Control Valves

We are in the process of developing a molded plastic spacer to replace our current machined spacer (16638-01) on the 2850 and 9500 control valves.

Until the new molded spacer becomes available, we will use our brass spacer (16638) in all 2850 and 9500 control valves, as well as in the seal/spacer service repair kits for these valves. We will continue to have two different part numbers for cold and hot water seal/spacer kits.

Below is a reference chart for seal/spacer kits:

	Valve	Kit Number	Seal Number	Seal Qty.	Spacer Number	Spacer Qty.
S t a n d a r d	2850	60129	16101	6	16638	5
	9500 Upper	60134	16101	5	16638	4
	9500 Lower	60133	16101	11	16638	8
					17092	1
H o t W a t e r	2850	60129HW	16101	6	16638	5
	9500 Upper	60134-01	16101	5	16638	4
	9500 Lower	60133-01	16101	11	16638	8
					17092	1
S i l i c o n e	2850	60129-10	16101-10	6	16638	5
	9500 Upper	60134-10	16101-10	5	16638	4
	9500 Lower	60133-10	16101-10	11	16638	8
					17092	1

As always, thank you for using Fleck controls.

Sincerely,  
Pentair Water Treatment, Inc.

Jay Runkle  
Technical Product Support