



# PERFORMANCE BULLETIN

Product     Application     Service     General    news from



January 21, 2003

## 14202 Screw Length Change

We have shortened the length of the 14202 screw, which holds the 1<sup>st</sup> meter and 2<sup>nd</sup> tank connection for the 9000 control valve. This new screw will also hold the 2<sup>nd</sup> tank connection for the new 9100 control valve. The change was needed for the 9100 control valve due to the length of the 14202 screw (8-32 x 3/8) is too long. The new screw will be part number 14202-01 and the size will be 8-32 x 5/16.

The new screw (14202-01) will work on older 9000 control valves as well as new 9000 control valves, but the old screw (14202) will not work on the 9100 valve.

Old



14202

New



14202-01

As always, thank you for using Fleck controls.

Sincerely,

Pentair Water Treatment, Inc.

Wayne Plouense  
Technical Sales/Support