



PERFORMANCE BULLETIN

Product Application Service General news from



May 21, 2003

New 559PE Chloramine Resistant Material Replaces the 16101-02 Silicone Seal

Effective immediately, we have changed the material of our Chloramine-resistant seals for the 2850 and 9500 valves from Silicone to a 559PE EPDM material. Silicone seals will no longer be available for the 2850 and 9500 as a valve option or for sale as a part.

The 559PE material has three times the Chloramine resistance of our current 560CD with improved molding capabilities over Silicone. The new 559PE EPDM seal will be Black in color with a **Green** dot as opposed to the **orange** Silicone seals.

New part numbers are as follows:

41113	Seal, 559PE	<i>Replaces</i>	16101-02	Seal, 2850 Silicone
60129-30	Seal & Spacer Kit, 2850, 559PE	<i>Replaces</i>	60129-10	Seal & Spacer Kit, 2850, Silicone
60133-30	Seal & Spacer Kit, 9500 Lower, 559PE	<i>Replaces</i>	60133-10	Seal & Spacer Kit, 9500 Lower, Silicone
60134-30	Seal & Spacer Kit, 9500 Upper, 559PE	<i>Replaces</i>	60134-10	Seal & Spacer Kit, 9500 Upper, Silicone

As always, thank you for using Fleck controls.

Sincerely,
Pentair Water Treatment, Inc.

Jay Runkle
Technical/Sales Support